



AVK Swing Check Valve (Series 41) Sample Specification

1. General.

- A. Swing check valves shall be of the flanged type and in full compliance with AWWA C508.
- B. Valves may be supplied with or without external lever with weight or spring.
- C. The pressure rating shall be 250 psi.
- D. Check valves shall be American AVK Series 41 or equal.
- E. Valve s shall be certified to ANSI/NSF 61.

2. Valve Bodies.

- A. Valve bodies shall be of ASTM A536 Ductile Iron.
- B. Flanges shall be in compliance with ANSI B16.1 Class 125.
- C. The body shall be designed so that it is an AWWA clear waterway design.
- D. Laying lengths shall comply with ANSI/ASME B16.10.

3. Valve Disc

- A. Disc shall be a carbon steel core completely encapsulated with EPDM.

4. Valve Hinge and Hinge Pin

- A. The hinge and hinge pin shall be constructed of AISI 316 stainless steel or fusion bonded epoxy coated ductile iron.
- B. Hinge bushing shall be bronze.
- C. A minimum of two O-rings shall be used to seal the hinge pin.

5. Protective Coatings

- A. All exposed ferrous surfaces except stainless steel shall be coated with a fusion bonded epoxy that shall comply with AWWWA C550.

AMERICAN AVK COMPANY

2155 NORTH MERIDIAN BLVD - MINDEN, NV 89423 - PH. (775) 552-1400 - FAX (775) 783-7502

6. End Connections.

- A. Flanged ends shall comply with ANSI/ASME B16.1, class 125 flanges

7. Maintenance

- A. The check valve shall be designed such that the disc, hinge, and bonnet can be removed as one assembly.

8. Testing

- A. Testing shall be performed in accordance with AWWA C508. Test results shall be furnished to the end user upon request.

