AVK Series 24 Ductile Iron Wet Barrel Hydrants

UL/FM Certificate of Compliance

This letter is to certify that the Series 24 ductile iron Wet Barrel Fire Hydrants manufactured by American AVK Company in Minden, Nevada, meet or exceed the standards established UL 246 and FM1511. The hydrants are listed with UL and are FM approved.

Each hydrant is tested, after assembly, to a static pressure of 400 psi. The AWWA, UL and FM working pressure is rated to 200 psi.

In addition, all American AVK fire hydrants have a 10 year limited warranty against manufacturing and material defects from the date of purchase.

If you have any questions or need further information, please feel free to contact us.

American AVK Company
2155 Meridian Blvd
Minden, NV 89423
Tel: (775) 552-1400
Fax: (775) 552-1031
sales@avkus.com
www.americanavk.com

Expect... AVK