AVK Series 41 Check Valves

AWWA C508 Certificate of Compliance

This letter is to certify that all 3-inch through 12-inch Series 41 resilient seated and bronze seated check valves manufactured by American AVK Company in Minden, Nevada, meet or exceed the standards established by AWWA for Swing Check Valves; ANSI/AWWA C508.

The valves are rated by American AVK Co. for a working pressure of 250 psi. Each valve is shell tested to 500 psi and seal tested for complete operation at 250 psi.

If you have any questions or need further information, please feel free to contact us.

American AVK Company
2155 Meridian Blvd
Minden, NV 89423
Tel: (775) 552-1400
Fax: (775) 552-1031
sales@avkus.com
www.americanavk.com